


# EC Type-Examination Certificate



Product Safety  
Functional  
Safety

www.tuv.com  
ID 0600000000



**Reg.-No.:** 01/205/5739.00/19

<b>Product tested</b>	Safety Relay Module	<b>Certificate holder</b>	IDEC CORPORATION 6-64, Nishimiyahara, 2-Chome Yodogawa-ku Osaka 532-0004 Japan
-----------------------	---------------------	---------------------------	---

<b>Type designation</b>	HR5S Series Details see actual "Revision List"
-------------------------	---

<b>Codes and standards</b>	EN ISO 13849-1:2015 EN ISO 13849-2:2012	EN 60947-5-1:2017 IEC 61000-6-7:2014
----------------------------	--	---

<b>Intended application</b>	The Safety Relay Module complies with the requirements of PL d / Cat. 2 (Basic type / OFF-delay types) and PL c / Cat. 2 (Simple type) of EN ISO 13849-1 and can therefore be used in applications up to these levels.
-----------------------------	--

<b>Specific requirements</b>	The instructions of the associated Installation and Operating Manual shall be considered.
------------------------------	---

It is confirmed, that the product under test complies with the requirements for machines defined in Annex I of the EC Directive 2006/42/EC.

Valid until 2024-11-08

The issue of this certificate is based upon an examination, whose results are documented in Report No. 968/FSP 1956.00/19 dated 2019-11-08.  
This certificate is valid only for products which are identical with the product tested.

Köln, 2019-11-08

Notified Body for Machinery, NB 0035

Dipl.-Ing. Eberhard Frejno


www.fs-products.com

www.tuv.com

 **TÜVRheinland**®  
Genau. Richtig.

TÜV Rheinland Industrie Service GmbH, Am Grauen Stein, 51105 Köln / Germany  
Tel.: +49 221 806-2434, Fax: +49 221 806-1354, E-Mail: industrie-service@de.tuv.com

10/201 10.17 D A4 © TÜV, TÜEV und TUV sind eingetragene Marken. Eine Nutzung und Verwendung bedarf der vorherigen Zustimmung.



Revision List

referred to on Certificate No.: 01/205/5739.00/19

Safety Relay Module HR5S Series



Safety related modules / components

Type Designation	Description	HW Version	Report-No.:	Certification Status
HR5S-C2S	Simple type	1.0	968/FSP 1956.00/19	Valid
HR5S-C2B	Basic type	1.0		
HR5S-C2D-T025	OFF-delay (0.25s) type	1.0		
HR5S-C2D-T050	OFF-delay (0.50s) type	1.0		
HR5S-C2D-T100	OFF-delay (1s) type	1.0		
HR5S-C2D-T200	OFF-delay (2s) type	1.0		
HR5S-C2D-T400	OFF-delay (4s) type	1.0		

Safety Manual / User documentation

Document No.	Description	Report-No.:	Certification Status
B-2134(0)	INSTRUCTION SHEET (Original Instructions) Safety Relay Module HR5S Series	968/FSP 1956.00/19	Valid

The content of this Revision List has been agreed between Manufacturer and Certification Body.

Revision:

Date	Rev.	Description / Changes	Author
2019-11-08	1.0	Initial creation, based on Report-No.: 968/FSP 1956.00/19	hs/A-FS

IDEC Corporation  
 2-6-64 Nishimiyahara, Yodogawa-ku  
 Osaka 532-0004 / Japan

File: 01\_205\_5739\_00\_19\_RL\_2019\_11\_08.docx



TÜV Rheinland Industrie Service GmbH  
 Automation - Functional Safety (A-FS)  
 Am Grauen Stein  
 51105 Köln / Germany