



IHTF.E353024 Luminaires for Use in Zone Classified Hazardous Locations

[Page Bottom](#)

Luminaires for Use in Zone Classified Hazardous Locations

[See General Information for Luminaires for Use in Zone Classified Hazardous Locations](#)

IDEC CORP

E353024

6-64 NISHIMIYAHARA 2-CHOME
YODOGAWA-KU, OSAKA 532-0004 JAPAN

Class I, Zone 1, AEx d IIB.

Luminaire, threaded for rigid conduit connection, Cat. No. EF1A-1, followed by 1 or 2, may be followed by 1, followed by W, may be followed by 1, may be followed by T or P, may be followed by S or C, may be followed by A or B, followed by N1, N2, M25, or M32, may be followed by A1 or A2, may be followed by additional letters and/or numbers. Insulation for supply conductors shall be suitable for 75°C.

Trademark and/or Tradename:



IDEC

[Last Updated](#) on 2014-11-13

[Questions?](#)

[Print this page](#)

[Terms of Use](#)

[Page Top](#)

© 2018 UL LLC

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2018 UL LLC".