

Testing & Certification

DEMKO A/S  
Lyskaer 8, PO box 514  
DK-2730 Herlev, Denmark

Phone: +45 44 85 65 65  
Fax: +45 44 85 65 00  
e-mail: demko@demko.dk



Idec Izumi Corp.  
7-31, Nishimiyahara 1-Chome,  
Yodogawa-ku  
Osaka 532  
Japan

Examinee: Peter Leonhardt

Your reference	Your letter	Our letter	Our reference	Ext.	Herlev
Cathy Allkins	1997-04-15		122371 PL	6266	1997-05-07

## Approval

DEMKO hereby grants approval of the following:

Emergency stop, push-button by latching with rotation  
single or double pole  
in thermoplastic enclosure  
with screw-type terminals for unprepared conductors  
pollution degree 3  
short-circuit protective device: 10 A low-voltage fuse, type D 01, lent  
conditional short-circuit current: 100 A  
impulse withstand voltage 2,5 kV  
utilization category: AC-15: 3,0 A, 250 V ~  
DC-13: 0,3 A, 125 V =

marked: Trade mark  
01) type HW series  
own make  
unenclosed, degree of protection provided by the emergency stop: IP 65

The product type has been tested according to EN 60947-5-1:1991.

The approval applies to products, strictly identical with the submitted and approved product type. If you make any alteration of the product, including the marking, you are obliged to inform DEMKO about this by letter.

The product may display the registered mark of approval ®.

The approval is valid until 2007-05-07 unless otherwise notified or the regulations are changed.

The submitted equipment has been destroyed.

Yours faithfully  
For DEMKO

  
N.B. Nielsen  
Section manager

A subsidiary of



Underwriters Laboratories Inc. ®

