

CERTIFICATE OF COMPLIANCE

Certificate Number E55996
Report Reference E55996-20020131
Date 2020-December-02

Issued to: IDEC CORP
6-64 NISHIMIYAHARA 2-CHOME
YODOGAWA-KUOSAKA 532-0004 JP

**This is to certify that
representative samples of**

SWITCHES, INDUSTRIAL CONTROL
See Addendum Page for Product Designation(s).

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 508 Standard for Industrial Control Equipment

Additional Information: See the UL Online Certifications Directory at
<https://iq.ulprospector.com> for additional information

This Certificate of Compliance does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/about/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number E55996
Report Reference E55996-20020131
Date 2020-December-02

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements

Switches, Industrial Control. Open Type Electronic Multi timers, Models GT3S, followed by 1 or 2, may be followed by E, followed by AF, followed by 20.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/about/locations/>

