



Certificate of Compliance

Certificate: 1766086

Master Contract: 166730

Project: 70198361

Date Issued: 2018-10-01

Issued to: IDEC Corporation
6-64 Nishimiyahara 2-Chome
Yodogawa-Ku, Osaka 532-0004
JAPAN

The products listed below are eligible to bear the CSA Mark shown



Issued by: *Reddiprasad Cheekoori*
Reddiprasad Cheekoori

PRODUCTS

CLASS - C321107 - INDUSTRIAL CONTROL EQUIPMENT-Miscellaneous Apparatus

Electronic timers, open type with dust cover, Series GT5P with suffix, contact rating 3A, 240V ac (resistive); 5A, 120V ac (resistive); 5A, 30V dc, input 200-240V ac, 100-120 V ac, 24V ac/dc or 12V dc.

Note: These devices are certified as components for use only in other certified equipment where the suitability of the combination is determined by the CSA International.



Certificate: 1766086
Project: 70198361

Master Contract: 166730
Date Issued: 2018-10-01

APPLICABLE REQUIREMENTS

CSA Std C22.2 No. 14 - Industrial Control Equipment