

CERTIFICATE OF COMPLIANCE

Certificate Number 20160208-E177168
Report Reference E177168-20150813
Issue Date 2016-February-08

Issued to: IDEC CORP
6-64 NISHIMIYAHARA 2-CHOME
YODOGAWA-KU
OSAKA 532-0004 JAPAN

**This is to certify that
representative samples of**

POWER CIRCUIT AND MOTOR-MOUNTED APPARATUS
USL, CNL: Miscellaneous Apparatus, Power Supply for use in
Industrial
Control Equipment, Models PS5R-VB05, -VB12, -VB24, -VC12, -
VC24, -VD24, -VF24, -VA05, -VA12, -VA24, -VE24, -VG24.

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: Standard for Industrial Control Equipment, UL 508
Standard for General Use Power Supplies, CSA C22.2 No.
107.1-01

Additional Information: See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number 20160211-E467154
Report Reference E467154-20150821
Issue Date 2016-FEBRUARY-11

Issued to: IDEC CORP
6-64 NISHIMIYAHARA 2-CHOME
YODOGAWA-KU
OSAKA 532-0004 JAPAN

**This is to certify that
representative samples of**

**POWER CIRCUIT AND MOTOR-MOUNTED APPARATUS
FOR USE IN HAZARDOUS LOCATIONS**

Power Supplies for use in Hazardous Locations, Class I, Division 2, Groups A, B, C and D Hazardous Locations. Industrial Control Equipment Power Supplies – Model PS5R V Series model nos -VB05, -VB12, -VB24, -VC12, -VC24, -VD24, -VF24, -VA05, -VA12, -VA24, -VE24, VG24.

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety:

ANSI/ISA-12.12.01-2015 and CAN/CSA C22.2 No. 213-15 – Standard for Nonincendive Electrical Equipment for Use in Class I and II, Division 2 and Class III, Divisions 1 and 2 Hazardous (Classified) Locations.

Additional Information:

See the UL Online Certifications Directory at www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

